

THE ISLAND WATER ASSOCIATION INC.

1998 WATER QUALITY REPORT

“Quality Water At A Reasonable Cost”



We are very pleased to provide you with our first Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is, and always has been, to provide you with a safe and dependable supply of drinking water. We are also pleased to report that our drinking water is safe and meets and exceeds all federal and state requirements.

Where Does Your Water Come From?



The Suwannee Aquifer lies approximately 700 to 900 feet below the surface of Sanibel and Captiva Islands. This is the raw water source that is used to produce the drinking water for island residents. This water is pumped from a series of wells to our Reverse Osmosis Water Treatment Plant located at 3651 Sanibel-Captiva Road. Our raw water source contains many minerals. It is brackish water that has a moderate salt content. The salt content of the raw water is the primary reason that R.O. is used as IWA's treatment technology. The picture on the left shows the R.O. trains that remove not only the salt, but many other minerals as well. The plant can produce 4.7 MGD of drinking water.

The Island Water Association Inc. routinely monitors for contaminants in your drinking water according to federal and state laws. The following table shows the results of our monitoring for the period, of January 1st to December 31st 1998. Monitoring results prior to this period are also displayed in the table. As water travels over the land or underground it can pick up substances such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (1-800-426-4791).

Definitions

MGD – million gallons per day.

Non-Detects (ND) – Laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) – One part per million is the equivalent of one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter – One part per billion is the equivalent of one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) – Picocuries per liter is a measure of the radioactivity in water.

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level – The “Maximum Allowed” (**MCL**) is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s (see below) as feasible using the best available treatment techniques.

Maximum Contaminant Level Goal – The “Goal” (**MCLG**) is the level of a contaminant in drinking water below which there is no known expected risk to health. MCLG’s allow for a margin of safety.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Table Of Contaminants

INORGANIC CONTAMINANTS						
Contaminant And Unit of Measurement	MCL/TT AL Violation (YES/NO)	Level Detected (IWA)	Range	MCLG	MCL	Likely Source of Contamination
Sodium (ppm)	NO	122.0	N/A	N/A	160	Salt water intrusion; Leaching from soil
Fluoride (ppm)	NO	0.18	N/A	4	4	Erosion of natural deposits
Lead (ppb)	NO	2.0	4 (number of sample sites above the action level)	0	AL=15	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	NO	0.14	0 (number of sample sites above the action level)	1.3	AL=1.3	Corrosion of household plumbing systems; Erosion of natural deposits
VOLATILE ORGANIC CONTAMINANTS						
TTHMs (ppb) Total Trihalo-Methanes	NO	6.0	N/A	0	100	By-product of drinking water chlorination
RADIOLOGICAL CONTAMINANTS						
Gross Alpha (pCi / L)	NO	3.2	2.8 – 3.6	0	15	Erosion of natural deposits

Lead

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using the water. Additional information is available from the Safe Drinking Water Hotline at (1-800-426-4791).

Radon

We constantly monitor the water supply for various constituents. We have detected Radon in the finished water supply in 2 out of 2 samples tested in 1997. There is no federal regulation for Radon in drinking water. Exposure to air transmitted Radon over a long period of time may cause adverse health effects.

Cryptosporidium

We also tested our finished and source waters for Cryptosporidium (a microbiological contaminant) in 1998 and are very pleased to report that there was no detection. This contaminant is most commonly detected where surface water is utilized as a treatment facilities source water. Our source water comes from depths of 700 to 900 feet below the surface of Sanibel, greatly reducing the risk of ever having a Cryptosporidium problem.

Sources and Types of Contaminants in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity, such as:

- (A) **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic tanks, agricultural livestock operations, and wildlife.
- (B) **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- (E) **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas and mining activities.

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (1-800-426-4791).

Other Useful Information

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for the public.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline at (1-800-426-4791)

To Our Customers:

We are pleased to report that your drinking water is safe and meets and exceeds all federal and state requirements. If you have any questions about this report or concerning your water utility, please contact our Production Manager (Philip Noe) at 1-941-472-1502. Additional copies of this report are available upon request. We want our valued customers to be informed about their water utility.

If you want to learn more, please attend our annual meetings that are held each spring at our main office. Watch for the "IWA Pipeline" newsletter in your mailbox for dates and times. Please visit our Web site at www.islandwater.com. Plant tours are also available by appointment.

We at The Island Water Association work around the clock to provide top quality drinking water to all customers connected to our system. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.